



- 1 A tactile text & braille sign must be placed on the wall that meets the handle side of the door & it must be 48" to 60" above the floor. Sign must be 1/4" thick.
- 2 The tactile text on the sign must have a beveled edge or rounded profile.
- 3 The gender neutral sign on the door must have two, 1/4" thick shapes & a non-glare finish. The circle shape must be contrasting to the door color & the triangle must have a 70% contrasting color to the circle.
- 4 The sign on the door must be horizontally centered in the middle of the door.
- 5 A 12" diameter circle represents a women's restroom, while a 12" equilateral triangle represents a men's restroom. A triangle imposed on a circle represents a gender neutral restroom.
- 6 The geometric sign can contain text or symbols or they can be left blank. No braille.
- 7 The geometric door sign must measure 60" from the floor to the center of the sign.
- 8 Braille dot height must be between .025" to .037" and they must be .059" to .063" in diameter.
- 9 Braille dot spacing is always measured from the center of a dot to the center of a dot. There should be .30" from the beginning of one braille letter to the beginning of the second letter. The top dots on the second line of braille must be .395" to .40" from the top of the first line.

